



# Unit Certificate

## UC -220001, Rev.0

Certificate Holder	Ferroamp Elektronik AB Domnarvsgatan 16 163 53, Spanga Sweden
PGU Type	EnergyHub 7 & 14kVA / XL 28kVA
Rated Power	14 / 28 kW
Rated Voltage	230/400 V
Rated frequency	50 Hz

This Unit Certificate approves the partly compliance to the following Standards and Guidelines on the basis of the Evaluation Report and objections listed on Page 2 of this Certificate.

- **37-GC-P0853** Global Certification Policy, Evaluation of Grid Code Compliance, Issue 9.0, 2021-01-26 on the basis of:
- **EN50549-1:2020-10** Requirements for generating plants to be connected in parallel with distribution networks – Part 1: Connection to a LV distribution network – Generation plants up to and including Type B

Changes at the PGU must be accepted by the Certification Body or the Unit Certificate loses its validity. The Unit Certificate is valid until 2027-01-27.

Bremen, 2022-01-28

Guido Bröring  
Global Head of Grid Integration  
DEWI Offshore and Certification Centre GmbH

